



State of New Hampshire  
DEPARTMENT OF ENVIRONMENTAL SERVICES

6 Hazen Drive, P.O. Box 95, Concord, NH 03302-0095  
(603) 271-2457 FAX (603) 271-7894



Therese Reger  
Four Seasons Tennis & Sports Center  
2572 Lisbon Road  
Lisbon, New Hampshire 03585

LETTER OF DEFICIENCY  
WMB PBF 02-49  
August 23, 2002

Dear Ms. Reger:

The Department of Environmental Services, Water Division ("DES") is required by RSA 485-A:26 to operate a program to ensure the health and safety of the public when using public bathing facilities such as pools and spas. To implement this program, DES has adopted administrative rules Env-Ws 1101-1105 to specify the design, operation, and maintenance requirements for public bathing facilities. DES reviews applications for new public bathing facilities and also inspects and tests the water in existing public bathing facilities to ensure that applicable requirements are being met.

On August 2, 2002, DES inspected the following public bathing facilities at the Four Seasons Tennis & Sports Center, in Lisbon, NH: the indoor swimming pool ("Pool") and the therapy pool ("Therapy Pool"). During this inspection the following deficiency was noted:


- 1 A recommendation to close and super chlorinate the Therapy Pool was issued on August 5, 2002. The inspection on August 2, 2002 revealed that the Therapy Pool was in violation of Env-Ws 1103.14 and unsafe for public use. The following bacterial violation was observed in the Therapy Pool water:
  - (a) Pursuant to Env-Ws 1103.14(a)(2) the maximum allowable Heterotrophic Plate Count (HPC) in public bathing facility water is five hundred colony-forming units per one milliliter (500 cfu/mL). The Therapy Pool water contained 1,080 cfu/mL.

A report outlining how compliance will be achieved with the cited deficiency should be submitted to DES within 30 calendar days from receipt of this letter. The report should include a copy of two weeks of water quality test results for all facilities (please do not send originals).

DES personnel will conduct another inspection at a later date to determine whether you have come into, and are maintaining, full compliance with RSA 485-A:26 and Env-Ws 1101-1105. After a violation of Env-Ws 1103.14, the facility will be required to pass two inspection in the following months. In the event that compliance is not achieved, DES may take further action, including seeking an administrative fine up to \$2,000 for each offense or referring the case to the NH Attorney General's Office for judicial action.

We appreciate your cooperation in this matter. Please contact Amy Wilson at (603) 271-7108 if you have any questions regarding this letter. Copies of Env-Ws 1101-1105 are available through the DES Public Information Center at (603) 271-2975 or via the Internet at <http://www.des.state.nh.us/pools/env1100.pdf>.

Sincerely,



Jody Connor  
Limnology Center Director

cc Mark Harbaugh, Enforcement Attorney, DES ✓  
Amy Wilson, Public Bathing Facility Coordinator, DES  
Karl Herzig, Health Officer, Town of Lisbon

H:\BIOLOGY\POOLS\Letters-LOD\LOD.02.49.doc